



NOTES

1. Concrete Grades:
Insitu concrete 20MPa
Extruded concrete 25MPa
2. Bedding:
To consist of 300mm (min) GAP65 subbase in roads and 100mm GAP40 in footpaths.
3. Jointing:
Extruded channels cracking control joints formed or saw cut to a minimum depth of 30mm at max 4.00m intervals for unreinforced channels and 6.00m (max) for reinforced channels/nib. If there is a footpath adjacent to the channel/nib the sawcut shall coincide with the concrete footpath joint.

PREPARED BY OPUS:



AUCKLAND CITY
Transport

HAURAKI GULF ISLANDS
CHANNELS

SCALE :	NTS.
DRAWN :	PH
ISSUE DATE :	11/2008
APPROVED :	
PLAN No.	ISSUE B
2008/0202	