

**NOTES**

1. Under Channel Drains are required.
2. For Type 2 Contraction Joints are to be saw cut at 5m max. centres. Saw cuts to be ¼ depth of concrete by 6mm wide.
3. All Privateways are to be drained to a Catchpit and connected to a Drainage System to the satisfaction of the Engineer.

4.


SUBGRADE CBR	SUBBASE REQUIRED		
	TYPE 1	TYPE 2	TYPE 3
≥ 7	150	0	50
5	200	100	100
≤ 3	350	150	200

PREPARED BY:




**AUCKLAND CITY**  
Transport

**HAURAKI GULF ISLANDS**  
URBAN PRIVATE WAY :  
FOUR DWELLINGS OR MORE

SCALE : NTS  
DRAWN : LJC  
ISSUE DATE : 1/2009  
APPROVED :   
PLAN No. 2008/0304  
ISSUE B