

NOTES:

1. MCB & Contactors shall be sized to suit (min. 20a)
2. Earth leakage (EL) protection to AS/NZS3000

